

Water Audit Validation Certificate

Part A: Provided by Validator

Audit Information:

Water Supplier Name: City of Pomona

PWS ID: 1910126

System Type: Potable

Audit Period: Calendar Year 2019

Utility Representation: Julie Carver, Steve Paz, Jason Interlicchia, Drew Williams

Validation Date: 08/05/2020

Call Time: 10:30am

Sufficient Supporting Documents Provided: Yes

Validation Findings& Confirmation Statements:

Key Audit Metrics:

Data Validity Score: 54

Data Validity Band (Level): Level III (51-70)

ILI: 2.20

Real Loss: 1,442.479 acre-ft./yr.

Apparent Loss: 335.468 acre-ft./yr.

Non-revenue water as percent of cost of operating system: 9.5%

Certification Statement by Validator:

This water loss audit report has been Level I validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit.

If not, rejected recommendations are included here.



Validator Information:

Water Audit Validator: Damian Martinez

Qualifications: Water Audit Validator Certificate issued by the CA-NV Section of the AWWA

Validator Provided

Water Audit Validation Certificate

Part B: Provided by Utility

Water Supplier Name: City of Pomona

Supplier ID Number: 1910126

Water Audit Period: Calendar Year 2019

Water Audit & Water Loss Improvement Steps:


Utility to provide steps taken in preceding year to increase data validity, reduce real loss and apparent loss as informed by the annual validated water audit:

The City will begin budgeting in the next fiscal year to begin more meter testing. The City is in the process of a meter replacement program, which should assist in increasing the data validity score. The department will continue to take steps to reduce real losses. The City has been using the No-DEZ truck for flushing, and continue to improve response times once a leak is detected and located

Utility Provided

Certification Statement by Utility Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, Water Audit and Loss Control Programs, Manual 36, Fourth Edition and in the Free Water Audit Software Version 5.

Executive Name (Print)	Executive Position	Signature	Date
Chris Diggs	Water Resources Director		8/10/20